

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR**

CLINTON WATER ASSOC - Kingwood Pike, WV3303128

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 1/1/2025 and 3/31/2025, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
27, MONITORING, ROUTINE (DBP), MAJOR Failure to monitor/report Trihalomethanes (TTHMs)	1/1/2025 to 3/31/2025

What happened? What is being done? (Describe corrective action)

Samples were collected on time. The lab, however, did not run the samples until after the hold times were past due. The lab did not make us aware of the issue, as we received sample results as if they were good. It was later realized that the samples were ran past hold time. It was past the sample collection period. We requested that the state allow us to run replacement samples but were denied the opportunity. This resulted in a violation for not monitoring TTHMs for that quarter. We will be more vigilant on inspecting our sample results and catching lab discrepancies earlier to be able to respond in time.

For more information, please contact Alan Westfall at 304-269-0072
(Contact name) (Phone number)
Or 703 Greenbag Rd, Morgantown, WV 26508
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **CLINTON WATER ASSOC - KINGWOOD PIKE**

State Water System ID #: WV3303128

Date Distributed: 1/29/2026