

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
FAILURE TO COMPLETE CORRECTIVE ACTIONS
 CLINTON WATER ASSOC - ROUTE 119, WV3303107

Our water system violated a State drinking water requirement. Even though these were not emergencies, you, as our customers, have a right to know what happened and what we did to correct the situation (See table below).

An on-site evaluation of our system is conducted on a regular basis. Results of the evaluation show significant deficiencies in our water system which must be addressed to the Office of Environmental Health Services- District Office. We did not correct these deficiencies by the required date, and therefore are in violation.

What should I do?

There is nothing you need to do at this time.

The table below lists the deficiencies that require corrective action.

Required Corrective Action	Corrective Action Required by:
Failure to correct significant deficiencies	Within 120 days of written notification
Identified on sanitary survey conducted on March 21, 2024	Due date was August 9, 2024

What happened? What is being done? (Describe corrective action)

A Sanitary Survey was conducted on March 21, 2024. During this visit the system received 4 significant deficiencies. 3 of the 4 required new screens on the tank and the 4th required the overflow pipe for the Taylor tank to be modified. All of these were completed by July 17th and submitted to the State. However, due to a clerical error it was not received in the proper format. We have revised our process for responding to the Sanitary Survey so that this does not happen again.

For more information, please contact Alan Westfall at 304-269-0072 (Phone Number) (Contact Name)
 or 160 John Street, Weston, WV 26452 (Mailing Address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by CLINTON WATER ASSOC - ROUTE 119

State Water System ID# WV3303107

Date Distributed _____